

FIRE TEST QUALIFICATION CERTIFICATE



Score (Europe) Ltd



Item	Butterfly Valve
Size	DN200 41101CS & 41001CS
Class	PN25
Serial No	No Data / Test direction flow behind disc
Body Material	ASTM A351 CF8M
Seal	EN10028-7 1.4436
Manufactured by	Sento Oy Hogfors
In accordance with job number	150794 COW
In accordance with drawing number	2529364a dated 16/02/00

The above valve was tested by **Score (Europe) Ltd** at their **Specialised Valve Research and Test Centre, Cowdenbeath, Scotland** and the results have been recorded as a **PASS**, having complied with the minimum performance requirements stated in specification

Test date	16/12/04
Other sizes qualified	DN200 (and above), 8" (and above)
Other pressure ranges qualified	150 & 300 PN 25 & 40

Tested by W. Hay / R. Hepburn

Witnessed by W. Campbell - Lloyds Register



This certificate must be read in conjunction with the full Score Test Report Number **150794-1**